

Annual Environmental Report

2024



Granard

D0187-02

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 GRANARD WWTP - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - GRANARD WWTP
 - 2.1.2 EFFLUENT MONITORING SUMMARY - GRANARD WWTP
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR GRANARD WWTP
 - 2.1.5 SLUDGE/OTHER INPUTS TO GRANARD WWTP

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

- 7.1 AMBIENT MONITORING SUMMARY

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER

This Annual Environmental Report has been prepared for D0187-02, Granard, in Longford in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There were no capital works, significant changes or operational changes undertaken in 2024.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Granard WWTP with a Plant Capacity PE of 3200, the treatment type is 2 - Secondary treatment.

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF2000D0187SW001	Granard WWTP	Treated	Non-Compliant	BOD, 5 days with Inhibition (Carbonaceous BOD) Kg/d ortho-Phosphate (as P) - unspecified mg/l Ortho-Phosphate Load (as P) Kg/d

1.4 LICENCE SPECIFIC REPORTING

Assessment / Report

There are no Licence Specific Reports included in this AER.

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 GRANARD WWTP - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - GRANARD WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
pH pH units	12	7.94	7.2
Total Nitrogen mg/l	12	66	28
ortho-Phosphate (as P) - unspecified mg/l	12	9.86	2.53
Ammonia-Total (as N) mg/l	12	33	16
COD-Cr mg/l	12	5590	586
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	12	26147 *	1139
Total Phosphorus (as P) mg/l	12	12	3.92
Suspended Solids mg/l	12	22540 *	1015
Hydraulic Capacity	N/A	3006	1157

* Very heavy fat in influent on 07/08/2024

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF2000D0187SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	12	N/A	N/A	15	Pass
Suspended Solids mg/l	35	87.5	N/A	12	N/A	N/A	5.9	Pass
pH pH units	6	9	N/A	12	N/A	N/A	7.42	Pass
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	4	8	N/A	12	N/A	N/A	1.1	Pass
BOD, 5 days with Inhibition (Carbonaceous BOD) Kg/d	1.91	N/A	N/A	12	3	N/A	1.3	Fail
Ammonia-Total (as N) mg/l	0.2	0.4	N/A	12	2	N/A	0.07	Pass

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
ortho-Phosphate (as P) - unspecified mg/l	0.15	0.3	N/A	12	3	N/A	0.119	Fail
Ortho-Phosphate Load (as P) Kg/d	0.07	N/A	N/A	12	6	N/A	0.119	Fail
Conductivity @20°C µS/cm	N/A	N/A	N/A	12	N/A	N/A	747	
Temperature °C	N/A	N/A	N/A	1	N/A	N/A	10	
Visual Inspection Descriptive	N/A	N/A	N/A	12	N/A	N/A	N/A	
E. Coli MPN/100ml	N/A	N/A	N/A	2	N/A	N/A	13976	
Faecal coliforms MPN/100ml	N/A	N/A	N/A	2	N/A	N/A	6272	
Total Phosphorus (as P) mg/l	N/A	N/A	N/A	12	N/A	N/A	0.18	
BOD - 5 days (Total) mg/l	N/A	N/A	N/A	1	N/A	N/A	1.00	
Enterococci (Intestinal) MPN/100ml	N/A	N/A	N/A	2	N/A	N/A	4272	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Total Nitrogen mg/l	N/A	N/A	N/A	12	N/A	N/A	14	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

Cause of Exceedance(s):

WWTP upgrade required to meet ELVs.

Significance of Results:

The WWTP is non compliant with the ELV's set in the Wastewater Discharge Licence. The impact on receiving waters is assessed further in Section 2.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF2000D0187SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Downstream	232842, 279341	RS26R040100	No	No	No	No	Poor

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**.

Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence for the following: BOD, 5 days with Inhibition (Carbonaceous BOD) Kg/d, Ortho-Phosphate (as P) - unspecified mg/l and Ortho-Phosphate Load (as P) Kg/d.

The ambient monitoring results do not meet the required EQS at the downstream monitoring location. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

As per the 3rd Cycle Upper Shannon Catchment Report (HA 26C), the significant pressures on the At Risk Rhine_010 waterbody are Agriculture and Urban Waste Water.

There is no upstream monitoring point. The WFD status downstream of the discharge is Poor.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - GRANARD WWTP

2.1.4.1 Treatment Efficiency Report - Granard WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
cBOD	481045	410	100
COD	247625	5672	98
SS	428805	2212	99
TN	11706	5071	57
TP	1656	67	96

Note: The above data is based on sample results for the number of dates reported.

2.1.4.2 Treatment Capacity Report Summary - Granard WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Granard WWTP	
Peak Hydraulic Capacity (m³/day) - As Constructed	2246
DWF to the Treatment Plant (m³/day)	749
Current Hydraulic Loading - annual max (m³/day)	3006
Average Hydraulic loading to the Treatment Plant (m³/day)	1157
Organic Capacity (PE) - As Constructed	3200
Organic Capacity (PE) - Collected Load (peak week)^{Note1}	1729
Organic Capacity (PE) - Remaining	1471
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - GRANARD WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2024.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
Breach of ELV	WWTP upgrade required to meet ELV	Yes	No

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2024	1
Number of Incidents reported to the EPA via EDEN in 2024	1
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2024 (No. of events)	Total volume discharged in 2024 (m ³)	Monitoring Status
SW002	233348, 279485	Yes	Low Significance	Meeting Criteria	21	14491	Monitored
SW003	233348, 279485	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
TBC	-, -	No	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
TBC	233451, 280925	No	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
TBC	234217, 281233	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Monitored*

* Volume was not available at the time of preparing this 2024 AER.

The contents presented in this table include the most up to date information available at the time of writing. Any TBC SWO(s) were identified as part of the ongoing National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much wastewater discharge by metered SWOs during the year (m³)?	14491
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	No

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0187-SIP.01	SW003 to be assessed and brought into compliance with DoECLG criteria	C	25/10/2022	No	Not Started		SW003 is being reassessed based on updated survey data. There is an ongoing WWTP upgrade project for Granard that will accommodate necessary upgrades to SW003 based on the outcome of the updated SWO assessment. Flow monitoring will be undertaken to establish compliance of SW003. Assessment/monitoring completed in 2024.

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
No additional improvements planned at this time.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Included in this AER
There is no Licence Specific Report Required in this AER Annual Review.		

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 26/04/2025

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of,

Eleanor Roche

Head of Environmental Regulation.

7 APPENDIX

Appendix

Appendix 7.1 - Ambient monitoring summary

Granard 2024 Ambient Monitoring Summary

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish National Grid Reference (Easting, Northing)	River Station Code	Receiving Waters Designation (Yes/No)			
			Bathing Water	Drinking Water	FWPM	Shellfish
Upstream Monitoring Point	N/A	N/A				
Downstream Monitoring Point	232842, 279341	RS26R040100	No	No	No	No

Note: Access issues to land preventing LA from getting Upstream samples.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Current WFD Status	cBOD	o-Phosphate (as P)	Ammonia (as N)
Downstream Monitoring Point	Poor	2.47	0.082	1.082
EQS		1.500	0.035	0.065

Granard 2024 Ambient Monitoring Data

Sample Date	pH pH units	BOD mg/ l	Suspended solids mg/l	Total Nitrogen as N mg/l	Total Ammonia as N mg/l	Ortho- Phosphate as P mg/l	DO mg/l	DO % sat	Faecal Coliforms cfu	E. coli cfu	Intestinal enterococci cfu	Temperature oC
10/01/2024	7.5	1.50	< 2.5	2.1	0.085	0.033	8.63	79.5				12.5
14/02/2024	7.32	< 1	5	2.5	0.225	0.057	7.44	66.8	921	2420	27	9.9
13/03/2024	7.26	1.30	<2.5	3.4	0.352	0.120	7.66	74.4				13
10/04/2024	7.23	10.00	11	55	6.19	0.051	8.5	81.3				12.8
08/05/2024	7.38	1.10	3	3.6	0.184	0.044	7.37	64.5				10.9
12/06/2024	7.19	1.20	3.5	4.5	0.168	0.054	10.86	96.9				9.1
10/07/2024	7.16	3.30	6.8	5.23	2.8	0.083	8.21	82.8				15.7
14/08/2024	8.22	1.50	< 2.5	1.37	< 0.02	0.130	10.36					14.8
11/09/2024	7.41	1.50		4.2	0.732	0.104	6.38	58.2	620	360	50	
09/10/2024	7.18	2.20	15	7.74	0.96	0.190	6.95	70.8				15.2
13/11/2024	7.28	1.00	2.5	3.13	0.155	0.065	5.94	51.5				9.3
04/12/2024	7.6	4.30	3	2.96	0.054	0.053	8.94	84.9				12
Mean	7.39	2.47	5.01	7.98	1.082	0.082	8.10	73.78	770.50	1390.00	38.50	12.29
95%ile	7.88	6.87	13.00	29.01	4.495	0.157	10.59	90.90	905.95	2317.00	48.85	15.45

Note: Where the concentration in the result is less than the limit of detection (LOD), a value of $LOD/\sqrt{2}$ was used in calculating the mean and 95%ile concentrations.