

Annual Environmental Report

2024



Derrintum

D0244-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 DERRINTURN WWTP - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - DERRINTURN WWTP
 - 2.1.2 EFFLUENT MONITORING SUMMARY - DERRINTURN WWTP
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR DERRINTURN WWTP
 - 2.1.5 SLUDGE/OTHER INPUTS TO DERRINTURN WWTP

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 SMALL STREAM RISK SCORE ASSESSMENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

- 7.1 AMBIENT MONITORING SUMMARY
- 7.2 SMALL STREAM RISK SCORE ASSESSMENT

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER

This Annual Environmental Report has been prepared for D0244-01, Derrinturn, in Kildare in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There were no capital works, significant changes or operational changes undertaken in 2024.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Derrinturn WWTP with a Plant Capacity PE of 1600, the treatment type is 3P - Tertiary P removal.

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF1400D0244SW001	Derrinturn WWTP	Treated	Non-Compliant	Ammonia-Total (as N) mg/l BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l ortho-Phosphate (as P) - unspecified mg/l Suspended Solids mg/l Total Phosphorus (as P) mg/l

1.4 LICENCE SPECIFIC REPORTING

Assessment / Report
Small Stream Risk Score Assessment

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 DERRINTURN WWTP - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - DERRINTURN WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Total Phosphorus (as P) mg/l	10	190	34
COD-Cr mg/l	10	24800	4567
Total Nitrogen mg/l	10	960	193
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	10	13080	2435
Suspended Solids mg/l	10	7740	1196
Hydraulic Capacity	N/A	1355	719

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF1400D0244SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	11	N/A	N/A	38	Pass
pH pH units	6	9	N/A	11	N/A	N/A	7.92	Pass
Suspended Solids mg/l	8	20	N/A	11	6	4	21	Fail
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	5	10	N/A	11	1	1	4.26	Fail
Total Phosphorus (as P) mg/l	0.5	0.6	N/A	11	2	1	0.521	Fail
Ammonia-Total (as N) mg/l	0.3	0.6	N/A	11	3	2	1.82	Fail
ortho-Phosphate (as P) - unspecified mg/l	0.19	0.37	N/A	11	2	1	0.160	Fail
Conductivity @20°C µS/cm	N/A	N/A	N/A	11	N/A	N/A	843	
Total Nitrogen mg/l	N/A	N/A	N/A	10	N/A	N/A	9.26	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

Cause of Exceedance(s):

Inadequate Operational Procedures/Training.

Significance of Results:

The WWTP is non compliant with the ELV's set in the Wastewater Discharge Licence. The impact on receiving waters is assessed further in Section 2.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF1400D0244SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Upstream	273020, 231285	RS14F010020	No	No	No	No	Poor
Downstream	269666, 230148	RS14F010050	No	No	No	No	Poor

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**.

Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results do not meet the required EQS at the downstream monitoring location. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in BOD, Ortho-P, Ammonia (as N), concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

As per the 3rd Cycle Barrow Catchment Report (HA 14), the significant pressures on the At Risk Figile_010 waterbody are Hydromorphology, Peat, Industry and Urban Waste Water.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - DERRINTURN WWTP

2.1.4.1 Treatment Efficiency Report - Derrinturn WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
COD	1057652	7179	99
TN	44623	1658	96
SS	276991	3855	99
cBOD	564004	794	100
TP	7814	97	99

Note: The above data is based on sample results for the number of dates reported.

2.1.4.2 Treatment Capacity Report Summary - Derrinturn WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Derrinturn WWTP	
Peak Hydraulic Capacity (m³/day) - As Constructed	1080
DWF to the Treatment Plant (m³/day)	360
Current Hydraulic Loading - annual max (m³/day)	1355
Average Hydraulic loading to the Treatment Plant (m³/day)	719
Organic Capacity (PE) - As Constructed	1600
Organic Capacity (PE) - Collected Load (peak week)^{Note1}	2052
Organic Capacity (PE) - Remaining	0
Will the capacity be exceeded in the next three years? (Yes/No)	Yes

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - DERRINTURN WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2024.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
Abatement equipment off-line	Dosing pump failure or maintenance at WWTP	Yes	No
Uncontrolled release	Plant or equipment breakdown at WWTP	No	Yes
Breach of ELV	Inadequate Operational Procedures/Training	Yes	No

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2024	3
Number of Incidents reported to the EPA via EDEN in 2024	3
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2024 (No. of events)	Total volume discharged in 2024 (m ³)	Monitoring Status
SW-2	270591, 232157	Yes	Low Significance	Meeting Criteria	0	0	Monitored

The contents presented in this table include the most up to date information available at the time of writing. Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much wastewater discharge by metered SWOs during the year (m ³)?	0
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
There are no Specified Improvement Programmes for this Agglomeration.							

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
No additional improvements planned at this time.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Included in this AER
D0244-01-Small Stream Risk Score Assessment	Yes	Yes

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	Yes
List reason e.g. changes to monitoring requirements	Ambient Monitoring Location Changes
Have these processes commenced?	No
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	Yes

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 23/04/2025

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of,

Eleanor Roche

Head of Environmental Regulation.

7 APPENDIX

Appendix
Appendix 7.1 - Ambient Monitoring Summary
Appendix 7.2 - Small Stream Risk Score Assessment

Derrinturn Ambient Monitoring Summary 2024

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish National Grid Reference (Easting, Northing)	EPA Feature Coding Tool code	Receiving Waters Designation (Yes/No)				Current WFD Status	Mean (mg/l)		
			Bathing Water	Drinking Water	FWPM	Shellfish		cBOD	o-Phosphate (as P)	Ammonia (as N)
Upstream Monitoring Point	273020, 231285	RS14F010020	No	No	No	No	Poor	1.483	0.011	0.033
Downstream Monitoring Point	269666, 230148	RS14F010050	No	No	No	No	Poor	1.983	0.031	0.091
<i>Difference</i>								<i>0.500</i>	<i>0.020</i>	<i>0.058</i>
EQS								1.500	0.035	0.065
% of EQS								33.333%	56.796%	89.599%

Derrinturn Ambient Monitoring Summary 2024

Upstream Results							
	Date	pH pH units	BOD mg/ l	Total Nitrogen mg/l	Ammonia mg/l	Ortho-Phosphate mg/l	DO mg/l
U/S	12/03/2024	7.6	< 1	2.9	0.069	< 0.01	7.3
U/S	30/04/2024	7.6	2	4.2	0.024	< 0.01	
U/S	15/05/2024	7.9	< 1	1.9	< 0.015	< 0.01	6.2
U/S	11/06/2024	7.9	< 1	1.4	0.048	0.01	8
U/S	02/07/2024	7.5	4	1.3	< 0.015	< 0.01	7.7
U/S	13/08/2024	7.8	2	< 1	0.056	< 0.01	7.6
U/S	11/09/2024	7.9	< 1	1.3	0.018	< 0.01	6.9
U/S	16/10/2024	8	1	1.5	< 0.015	0.04	8.7
U/S	13/11/2024	8	2	1.4	0.073	0.01	8.6
U/S	04/12/2024	7.8	1	3.6	< 0.015	< 0.01	9.6
Mean		7.800	1.483	2.021	0.033	0.011	7.844
95%ile		8.000	3.100	3.930	0.071	0.027	9.240

Downstream Results							
	Date	pH pH units	BOD mg/ l	Total Nitrogen mg/l	Ammonia mg/l	Ortho-Phosphate mg/l	DO mg/l
D/S	12/03/2024	7	<1	3.7	0.47	0.02	8.2
D/S	30/04/2024	7.9	6	2	<0.015	<0.010	
D/S	15/05/2024	8	2	2.1	0.15	<0.010	9
D/S	11/06/2024	7.6	3	3.2	0.036	0.02	9
D/S	02/07/2024	7.6	< 1	2.9	0.041	0.15	6.9
D/S	13/08/2024	7.5	< 1	2.8	0.071	0.03	6.5
D/S	11/09/2024	7.9	1	1.1	<0.015	<0.010	6.6
D/S	16/10/2024	7.4	3	4.7	0.025	0.05	6.1
D/S	13/11/2024	8	2	1.6	0.088	0.01	8.3
D/S	04/12/2024	7.8	<1	2.6	<0.015	<0.01	10.5
Mean		7.670	1.983	2.670	0.091	0.031	7.900
95%ile		8.000	4.650	4.250	0.326	0.105	9.900

Note: Where the concentration in the result is less than the limit of detection (LOD), a value of $LOD/\sqrt{2}$ was used in calculating the mean and 95%ile concentrations.

Kildare County Council

Derrinturn Small Stream Risk Score 2024

Mícheál McHugh Jewell, Daniel Dunleavy



AQUAFACT
APEM Group

AQUAFACT Ref: P14738

December 2024

COMMERCIAL IN CONFIDENCE

Client: Kildare County Council

Address: Devoy Park, Naas Co Kildare W91 X77F

Reference no: P14738

Date of issue: 02/12/2024

AQUAFACt contact: Dr Eddie McCormack

Position: Associate Director

E-mail: eddie@aquafact.ie

Telephone: +353 (0) 91 756812

Website: www.aquafact.ie

Address: AQUAFACt International Services Ltd,
9A Liosban Business Park,
Tuam Road,
Galway,
Ireland.
H91 K120

Registered in Ireland: No. 493496

Tax Reference Number: 97733840

Tax Clearance Number: 559674

Report Approval Sheet

Client	Kildare County Council
Report Title	Derrinturn Small Stream Risk Score 2024
Job Number	P14738
Report Status	Final
Issue Date	02/12/2024

Rev	Status	Issue Date	Document File Name	Author (s)	Approved by:
1	Draft	08/11/2024	P14738_Derrinturn_SSRS_Nov_2024_Draftv1	Mícheál McHugh Jewell, Daniel Dunleavy	E. McCormack
2	Final	02/12/2024	P14738_Derrinturn_SSRS_Nov_2024_Final	Mícheál McHugh Jewell, Daniel Dunleavy	E. McCormack



Table of Contents

1. Introduction	1
2. Methodology	1
2.1 Sampling	1
2.2 Small Stream Risk Score	2
3. Results	3
4. Derrinturn WWTP Comparison 2016 to 2024	4
5. References	5
Appendix 1 – Site photos	6
Appendix 2 – SSRS Data Sheets	10

Table of Figures

Figure 2-1: Upstream and Downstream positions on the River Figile at Derrinturn	1
Figure 4-1: SSRS between Upstream and Downstream sites since 2015	4

List of Tables

Table 2.1: Derrinturn SSRS station coordinates.	2
Table 2.2: SSRS Categories	2
Table 3.1: Taxa list and relative abundance scores	3
Table 3.2: Biological sampling results	3
Table 4.1: Derrinturn SSRS Comparison 2016-2024	4



List of Appendices

Appendix 1: Site Photos

Appendix 2: SSRS Datasheets

List of Acronyms/Glossary

D/S	Downstream
EPA	Environmental Protection Agency
G.O.L.D	Gastropods, Oligochaetes, Dipterans
IFI	Inland Fisheries Ireland
SSRS	Small Stream Risk Score
U/S	Upstream
WFD	Water Framework Directive
WRBD	Western River Basin District
WWTP	Wastewater Treatment Plant

1. Introduction

AQUAFAC was contracted by Kildare County Council to carry out an SSRS assessment of the watercourse in the vicinity of the discharge pipe of Derrinturn wastewater treatment plant. Field surveys were carried out upstream and downstream of the discharge point. The sampling was carried out on the 15th of October 2024.

2. Methodology

2.1 Sampling

Two kick samples were taken (See Figure 2.1 and Table 2.1). The two-minute kick and one minute stone wash sampling method was employed to collect samples of macroinvertebrates for analysis. This involved placing a standard hand net of pore size 500µm in the river, facing upstream and disturbing the riverbed in front of the net mouth. The surveyor then moved in a diagonal direction upstream to ensure that different micro-habitats were included in the sample. The kick sample method dislodges macroinvertebrates from the substrates and submerged plant material. This was continued for approximately two minutes and followed by one minute of stone washing (Lucey *et al.*, 1999).

The macroinvertebrate assemblages of each sample were identified and counted on the riverbank. The details of the macroinvertebrate assemblages were recorded on data sheets. The resulting species list was then used to assign the SSRS score to the sampled streams. The IFI’s 2010 Biosecurity Protocol for Field Survey Work document was followed during sampling. Nets and all other equipment were thoroughly disinfected between stations.



Figure 2-1: Upstream and Downstream positions on the River Figle at Derrinturn

Table 2.1: Derrinturn SSRS station coordinates.

Station	Latitude	Longitude
Derrinturn Upstream	53.3264963	-6.926851
Derrinturn Downstream	53.3170562	-6.9557887

2.2 Small Stream Risk Score

The Small Streams Risk Score (SSRS) is a biological risk assessment system for identifying rivers that are 'at risk' of failing to achieve the 'good' water quality status goals of the Water Framework Directive (WFD). It was developed by the Environmental Protection Agency (EPA) in association with the Western River Basin District (WRBD) in 2006 and revised in 2009.

The SSRS method is a rapid field methodology for risk assessment that is based solely on macroinvertebrate indicators of water quality and their well-understood response to pollution. Importantly, the SSRS score indicates whether or not the stream is at risk from pollution and not the ecological health of the stream. The SSRS score ranges from 0-11.2.

Table 2.2: SSRS Categories

SSRS Range	Category
<6.5	Stream at Risk (AR)
>6.5-7.25	Indeterminate/Stream may be at risk
>7.25	Probably not at risk (PNAR)

3. Results

The upstream station recorded a lower SSRS score. However, both the upstream and downstream stations were categorised as ‘Stream at risk’ of not meeting Good status. The substrate at the upstream station was mud with a depth of approximately 5-10cm. Leaf litter was abundant, and the velocity of the stream was slow. The downstream station substrate was a mix of cobbles and gravel with some slight siltation. The velocity was moderate. There was cattle access both above and below the downstream station. Macrofaunal assemblages were similar at both stations with GOLD Group taxa far outnumbering a small number of trichoptera.

Table 3.1: Taxa list and relative abundance scores

Taxa	Upstream	Downstream
Trichoptera		
Glossosomatidae		2
Limnephilidae	2	1
Phryganeidae	1	
G.O.I.D		
<i>Lumbriculus</i>		4
<i>Planorbis</i>	1	
Naididae	2	
Chironomidae	5	3
Asellus	Common	Absent

Table 3.2: Biological sampling results

Station	SSRS Score	SSRS Category
Derrinturn Upstream	2.4	Stream at Risk (AR)
Derrinturn Downstream	3.2	Stream at Risk (AR)

4. Derrinturn WWTP Comparison 2016 to 2024

Table 4.1 compares the SSRS results from 2016 to 2023. Figure 4.1 displays the trend over time (scores <6.5 are deemed At Risk). Both upstream and downstream sites have been ‘at risk’ since 2016. The highest SSRS score in that period was 3.2 both upstream and downstream. A tributary joins the stream from the east between the upstream and downstream stations, it is not known if any contamination enters the stream from this point. Just upstream of the downstream station the stream is culverted under the Grand Canal which could be impacting on water quality.

Table 4.1: Derrinturn SSRS Comparison 2016-2024

Year	U/S SSRS	U/S Risk Category	D/S SSRS	D/S Risk Category
2024	2.4	AR	3.2	AR
2023	0.8	AR	0.8	AR
2022	0.8	AR	1.6	AR
2021	2.4	AR	0.8	AR
2020	1.6	AR	3.2	AR
2019	3.2	AR	1.6	AR
2018	1.6	AR	2.4	AR
2017	3.2	AR	1.6	AR
2016	3.2	AR	2.4	AR




Figure 4-1: SSRS between Upstream and Downstream sites since 2015

5. References

- EPA. 2015. Guidance on Application and Use of the SSRS in Enforcement of Urban Waste Water Discharge Authorisations in Ireland. <https://www.epa.ie/publications/compliance--enforcement/waste-water/SSRS-in-Enforcement-of-UWWDAs.pdf> Accessed September 2021.
- Lucey, J., Bowman, J.J., Klabby, K.J., Cunningham, P., Lehane, M., MacCarthaigh, M., McGarrigle, M.L. and Toner, P.F. 1999. Water Quality in Ireland, 1995 – 1997. EPA.

Appendix 1 – Site photos



Derrinturn Downstream looking downstream



Derrinturn Downstream looking upstream



Derrinturn Upstream looking downstream




Derrinturn Upstream looking upstream

Appendix 2 – SSRS Data Sheets

River: FIGILE		Code: 14F01005 Date: 15/10/2024 Time:	
Station no. DOWNSTREAM		Location: DERRINTURN	
Stream Order:		Grid (6 figure): 269657, 230144	
Field Chemistry		Stream flow: Riffle <input checked="" type="checkbox"/> Riffle/Gate <input type="checkbox"/> Slow flow	
DO%	90.96	Shading: High - Moderate - Low - None	
DO mg/l	7.82	Cattle access Y: upstream - downstream or N	
Temp (°C)	11.90	Photos <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	
Conductivity		Sewage Fungus: None - Present - Moderate - Abundant	
pH	7.46	Sampled in Minutes: Pond net x 2 Stone wash x 1 Weed sweep x	
Bank width (cm)	300	Sewage Fungus: None - Present - Moderate - Abundant	
Wet width (cm)	200	Sewage Fungus: None - Present - Moderate - Abundant	
Avg Depth (cm)	15-20	Sewage Fungus: None - Present - Moderate - Abundant	
Staff gauge		Sewage Fungus: None - Present - Moderate - Abundant	
Velocity	Colour	Sewage Fungus: None - Present - Moderate - Abundant	
Torrential	None	Sewage Fungus: None - Present - Moderate - Abundant	
Fast	Slight	Sewage Fungus: None - Present - Moderate - Abundant	
Moderate	Moderate	Sewage Fungus: None - Present - Moderate - Abundant	
<input checked="" type="checkbox"/> Slow	High	Sewage Fungus: None - Present - Moderate - Abundant	
Very slow		Sewage Fungus: None - Present - Moderate - Abundant	
Clarity	Discharge	Sewage Fungus: None - Present - Moderate - Abundant	
Very clear	Flood	Sewage Fungus: None - Present - Moderate - Abundant	
<input checked="" type="checkbox"/> Clear	<input checked="" type="checkbox"/> Normal	Sewage Fungus: None - Present - Moderate - Abundant	
Slightly turbid	Low	Sewage Fungus: None - Present - Moderate - Abundant	
Highly turbid	Very Low	Sewage Fungus: None - Present - Moderate - Abundant	
	Dry	Sewage Fungus: None - Present - Moderate - Abundant	
	Recent Flood	Sewage Fungus: None - Present - Moderate - Abundant	
General Comments:			
Macroinvertebrate Composition			
The macroinvertebrates are divided into the following 5 specific groups: * Group 1 = Ephemeroptera (3-tails) - note that tails may be damaged during sampling * Group 2 = Plecoptera (2-tails) - note that tails may be damaged during sampling * Group 3 = Trichoptera * Group 4 = G.O.L.D (Gastropoda, Oligochaeta and Diptera) * Group 5 = Aseflus * Calculate the total number of taxa and relative abundance of each macroinvertebrate group below: (Abundance - Ab)			Relative Abundance 1-5 1 6-20 2 21-50 3 51-100 4 101+ 5
Ephemeroptera:		Plecoptera:	
<i>Ecdyonurus</i> Ab		<i>Leuctra</i> Ab	
<i>Rhythrogena</i> Ab		<i>Isoperla</i> Ab	
<i>Heptagenia</i> Ab		<i>Protonemura</i> Ab	
<i>Ephemerella</i> Ab		<i>Amphimura</i> Ab	
<i>Caenis</i> Ab		<i>Pleco</i> Ab	
<i>Paraleptophlebia</i> Ab		<i>Dinocras</i> Ab	
<i>Ephemerella danica</i> Ab		Other Plecop Ab	
Other Ephem Ab		Other Plecop Ab	
Total no. of taxa	Total Relative Abundance	Total no. of Taxa	Total Relative Abundance
4	5	2	7
Trichoptera:		G.O.L.D:	
Hydropsychidae Ab		<i>Lymnaea</i> (G) Ab	
Polycentropodidae Ab		<i>Polycentropus</i> (G) Ab	
<i>Rhyacophila</i> Ab		<i>Plecoptera</i> (G) Ab	
Plecoptera Ab		<i>Anisus</i> (G) Ab	
Limnephilidae Ab		<i>Physa</i> (G) Ab	
Sericoptomatidae Ab		<i>Lumbriculus</i> (O) Ab	
Glossosomatidae Ab		<i>Eisenia</i> (O) Ab	
Lelidostomatidae Ab		<i>Tubificoides</i> (O) Ab	
Other Trichoptera Ab		Chironomidae (D) Ab	
Total no. of Taxa	Total Relative Abundance	Total no. of Taxa	Total Relative Abundance
4	5	2	7
NOTE: <i>Baetis</i> is an Ephemeropteran and is the most commonly occurring invertebrate genus in streams in Ireland. It is vital that <i>Baetis</i> is not counted in SSRS. See Appendix B for more details on how to identify <i>Baetis</i> .		NOTE: Aseflus must be recorded as absent if none are found	

Downstream

Step 1. Calculate the Index Score by circling the appropriate box representing the total number of taxa and the total abundance calculated from **each macroinvertebrate group** calculated from page 1 of the recording sheet and enter in to the boxes in Step 2.



Step 3. Calculate the Total Index Score, the Average Index Score and the SSR Score using the boxes below

Total Index Score (TIS) sum (a+b+c+d+e) **8** Average Index Score (AIS) TIS/5 (5 for 5 groups) **1.6** SSR Score (AIS x 2) **3.2**

Step 4. Assess the stream by comparing the final SSR score with the categories below and tick the appropriate box

> 7.25 Probably not at risk > 6.5 – 7.25 Indeterminate Stream may be at risk < 6.5 Stream at risk

Surveyor (signed): Michael Name (print): MICHAEL MCHUGH Date: 31 / 10 / 24
JEWELL

Downstream II


River: FIGILE	Code: 14F010011	Date: 15/10/24	Time:
Station no. UPSTREAM	Location: DERRINTURN ASWI-TV	Grid (6 figure): 271514, 23178	
Field Chemistry		Stream Order:	Stream flow: Rifle Rifle/Glide Slow flow
DO%		Modifications: Y/N Canalised-widened-bank erosion-arterial drainage	
DO mg/l		Dominant Types:	
Temp (°C)		Bedrock	
Conductivity		Boulder (>128mm)	
pH		Cobble (32-128mm)	
Bank width (cm)		Gravel (8-32mm)	
Wet width (cm)		Fine Gravel (2-8mm)	
Avg Depth (cm)		Sand (0.25-2mm)	
Staff gauge		Silt (<0.25mm)	
Velocity	Colour	Slope: Low - Medium - High - Very High	Shading: High - Moderate - Low - None
Torrential	None	Geology: Calcareous-Siliceous-Mixed	Cattle access: Y N Upstream - downstream or N
Fast	Slight	Substratum Condition: Calcareous-Compacted	
Moderate	Moderate	Substratum:	
Slow	High	Stoney bottom-Muddy bottom-Mud over stones	Photos: Y N
Very slow		Degree of siltation: Clean-Slight-Moderate-Heavy	
Clarity	Discharge	Depth of mud: None <1cm: 1-5cm: 5-10cm: >10cm	
Very clear	Flood	Litter: None - Present - Moderate - Abundant	
Clear	Normal	Filamentous Algae:	Sewage Fungus:
		None - Present - Moderate - Abundant	None - Present - Moderate - Abundant
Highly turbid	Recent Flood	Rain land use u/s:	Sample retained:
		Pasture	Urban
		Bog	Tillage
		Forestry	Other
			Y N
General Comments:			

Macroinvertebrate Composition		Relative Abundance	
The macroinvertebrates are divided into the following 5 specific groups:			
<ul style="list-style-type: none"> Group 1 = Ephemeroptera (3-tails) - note that tails may be damaged during sampling Group 2 = Plecoptera (2-tails) - note that tails may be damaged during sampling Group 3 = Trichoptera Group 4 = G.O.L.D (Gastropods, Oligochaeta and Diptera) Group 5 = Aseelus 			
Calculate the total number of taxa and relative abundance of each macroinvertebrate group below: (Abundance - Ab)			
Ephemeroptera:	<i>Ecdyonurus</i> Ab	Plecoptera:	<i>Leuctra</i> Ab
	<i>Rhythrogena</i> Ab		<i>Isoperla</i> Ab
	<i>Hoptagenia</i> Ab		<i>Protonemura</i> Ab
	<i>Ephemerella</i> Ab		<i>Amphinemura</i> Ab
	<i>Caenis</i> Ab		<i>Pera</i> Ab
	<i>Paraleptophlebia</i> Ab		<i>Chironax</i> Ab
	<i>Ephemera danica</i> Ab		Other Plecop Ab
	Other Ephem Ab		Other Plecop Ab
Total no. of taxa 0	Total Relative Abundance 0	Total no. of Taxa 0	Total Relative Abundance 0
Trichoptera:	G.O.L.D:	Chironomidae (O) Ab 5	Aseelus:
<i>Hydropsychidae</i> Ab	<i>Lymnaea</i> (G) Ab	<i>Chironomus</i> (O) Ab	Absent
<i>Polycentropodidae</i> Ab	<i>Potamopyrgus</i> (G) Ab	<i>Simuliidae</i> (O) Ab	Few/Low
<i>Amya</i> (G) Ab	<i>Pisum</i> (G) Ab	<i>Dicranota</i> (O) Ab	Common/Numerous
<i>Phlebotomidae</i> Ab	<i>Ancylus</i> (G) Ab	<i>Ticulidae</i> (O) Ab	
<i>Limnephilidae</i> Ab	<i>Physa</i> (G) Ab	<i>Ceratopogonidae</i> (O) Ab	
<i>Sericostomatidae</i> Ab	<i>Lumbriculus</i> (O) Ab	Other GOLD Ab	
<i>Glossosomatidae</i> Ab	<i>Eisenia</i> (O) Ab		
<i>Leuctostomatidae</i> Ab	<i>Tubificoides</i> (O) Ab		
Other Trichoptera Ab			
Total no. of Taxa 2	Total Relative Abundance 3	Total no. of Taxa 4	Total Relative Abundance 9

NOTE *Baetis* is an Ephemeropteran and is the most commonly occurring Invertebrate genus in streams in Ireland. It is vital that *Baetis* is not counted in SSRS. See Appendix B for more details on how to identify *Baetis*.

Upstream

Step 1. Calculate the Index Score by circling the appropriate box representing the total number of taxa and the total abundance calculated from **each macroinvertebrate group** calculated from page 1 of the recording sheet and enter in to the boxes in Step 2.



Step 3. Calculate the Total Index Score, the Average Index Score and the SSR Score using the boxes below

Total Index Score (TIS) sum (a+b+c+d+e) **6** Average Index Score (AIS) TIS/5 (5 for 5 groups) **1.2** SSR Score (AIS x 2) **2.4**

Step 4. Assess the stream by comparing the final SSR score with the categories below and tick the appropriate box

> 7.25 Probably not at risk > 6.5 – 7.25 Indeterminate Stream may be at risk <6.5 Stream at risk

Surveyor (signed): David Dunleavy Name (print): DAVID DUNLEAVY Date: 01 / 11 / 2024

Upstream II