

Annual Environmental Report

2024



Kilpedder

D0416-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 KILPEDDER WWTP - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - KILPEDDER WWTP
 - 2.1.2 EFFLUENT MONITORING SUMMARY - KILPEDDER WWTP -
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR KILPEDDER WWTP
 - 2.1.5 SLUDGE/OTHER INPUTS TO KILPEDDER WWTP

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 PRIORITY SUBSTANCES ASSESSMENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

- 7.1 AMBIENT MONITORING SUMMARY

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER

This Annual Environmental Report has been prepared for D0416-01, Kilpedder, in Wicklow in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There were no capital works, significant changes or operational changes undertaken in 2024.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Kilpedder WWTP with a Plant Capacity PE of 600, the treatment type is 2 - Secondary treatment.

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF3400D0416SW001	Kilpedder WWTP	Treated	Compliant	N/A

1.4 LICENCE SPECIFIC REPORTING

Assessment / Report

There are no Licence Specific Reports included in this AER.

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 KILPEDDER WWTP - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - KILPEDDER WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
BOD, 5 days with Inhibition (Carbonaceous) mg/l	8	129	43
Suspended Solids mg/l	8	370	66
COD-Cr mg/l	8	705	158
Hydraulic Capacity	N/A	784	357

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF3400D0416SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	8	N/A	N/A	17	Pass
Suspended Solids mg/l	35	87.5	N/A	8	N/A	N/A	5.95	Pass
pH pH units	6	9	N/A	8	N/A	N/A	7.72	Pass
BOD, 5 days with Inhibition (Carbonaceous) mg/l	8	16	N/A	8	N/A	N/A	2.64	Pass
Ammonia-Total (as N) mg/l	0.7	1.4	N/A	8	N/A	N/A	0.243	Pass
ortho-Phosphate (as P) - unspecified mg/l	0.4	0.48	N/A	8	N/A	N/A	0.113	Pass

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

Cause of Exceedance(s):

Not applicable.

Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF3400D0416SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Upstream	326725, 208929	RS10K010120	No	No	No	No	Poor
Upstream	326685, 208893	RS10K680080	No	No	No	No	Poor
Downstream	326921, 208995	RS10K010160	No	No	No	No	Poor

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**.

Significance of Results:

The coastal/transitional ambient monitoring results do not meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results do not meet the required EQS at the upstream (at RS10K680080) and the downstream monitoring locations. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in BOD, Ortho-P & Ammonia (when compared to Upstream Station RS10K010120) and BOD & Ortho-P (when compared to Upstream Station RS10K010180) concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are unknown.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - KILPEDDER WWTP

2.1.4.1 Treatment Efficiency Report - Kilpedder WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
cBOD	5960	368	94
COD	21740	2333	89
SS	9084	830	91

Note: The above data is based on sample results for the number of dates reported.

2.1.4.2 Treatment Capacity Report Summary - Kilpedder WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Kilpedder WWTP	
Peak Hydraulic Capacity (m ³ /day) - As Constructed	405
DWF to the Treatment Plant (m ³ /day)	135
Current Hydraulic Loading - annual max (m ³ /day)	784
Average Hydraulic loading to the Treatment Plant (m ³ /day)	357
Organic Capacity (PE) - As Constructed	600
Organic Capacity (PE) - Collected Load (peak week) ^{Note1}	670
Organic Capacity (PE) - Remaining	0
Will the capacity be exceeded in the next three years? (Yes/No)	Yes

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - KILPEDDER WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2024.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
There were no reportable incidents in 2024.			

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2024	0
Number of Incidents reported to the EPA via EDEN in 2024	0
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2024 (No. of events)	Total volume discharged in 2024 (m ³)	Monitoring Status
SW2	326709, 208914	Yes	Low Significance	Meeting Criteria	111	2846	Monitored
TBC	326681, 208890	Yes	Low Significance	Not Meeting Criteria	Unknown	Unknown	Not Monitored

The contents presented in this table include the most up to date information available at the time of writing. Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much wastewater discharge by metered SWOs during the year (m ³)?	2846
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	No
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	No

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0416-SIP:01	Upgrade Kilpedder WWTP to provide phosphorus removal	C	31/12/2019	Yes	Works Completed		

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
No additional improvements planned at this time.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Included in this AER
D0416-01-Priority Substances Assessment	Yes	No

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	Yes
List reason e.g. changes to monitoring requirements	Ambient Monitoring Location Changes
Have these processes commenced?	No
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 21/02/2025

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of,

Eleanor Roche

Head of Environmental Regulation.

7 APPENDIX

Appendix

Appendix 7.1 - Ambient monitoring summary

Kilpedder 2024 Ambient Monitoring Summary

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish National Grid Reference (Easting, Northing)	EPA Feature Coding Tool code	Receiving Waters Designation (Yes/No)			
			Bathing Water	Drinking Water	FWPM	Shellfish
Upstream No. 1 Monitoring Point	326725, 208929	RS10K010120	No	No	No	No
Upstream No. 2 Monitoring Point	326685, 208893	RS10K010180	No	No	No	No
Downstream Monitoring Point	325921, 208995	RS10K010160	No	No	No	No

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Current WFD Status 2016-2021	cBOD	o-Phosphate (as P)	Ammonia (as N)
Upstream No. 1 Monitoring Point	Poor	0.825	0.0145	0.033
Upstream No. 2 Monitoring Point	Poor	0.800	0.0208	0.098
Downstream Monitoring Point	Poor	1.275	0.0270	0.068
<i>Difference between Upstream No. 1 and Downstream</i>		<i>0.450</i>	<i>0.013</i>	<i>0.035</i>
<i>Difference between Upstream No. 2 and Downstream</i>		<i>0.475</i>	<i>0.006</i>	<i>-0.030</i>
EQS		1.500	0.035	0.065
% of EQS # 1		30.000%	35.714%	53.846%
% of EQS #2		31.667%	17.806%	-46.154%

Kilpedder 2024 Ambient Monitoring Data

			Biological Oxygen Demand	Conductivity @ 20°C	Ortho-Phosphate P	Ammonium NH ₄ -N	Total Oxidised Nitrogen N	Dissolved Oxygen	Nitrite N	pH	Dissolved Oxygen % Saturation	Temperature
Station	Location	Sample Date	mg/l	µS/cm	mg/l	mg/l	mg/l	mg/l	mg/l	pH units	% O2	Degrees C
RS10K010120	U/S Kilpedder Wwtp	09/01/2024	1	501	0.013	0.02	4.1	11.5	< 0.005	7.6	98	8.1
RS10K010120	U/S Kilpedder Wwtp	09/04/2024	0.9	866	0.017	0.06	3.7	10	0.005	7.5	89	10
RS10K010120	U/S Kilpedder Wwtp	06/08/2024	0.9	400	0.023	0.04	4.8	10.7	< 0.005	8.1	100	12.3
RS10K010120	U/S Kilpedder Wwtp	08/10/2024	0.5	462	0.005	0.01	4.1	10	0.0025	7.4	92	11.4
		Mean	0.8250	557.2500	0.0145	0.0325	4.1750	10.5500	0.0050	7.6500	94.7500	10.4500
		95%ile	0.9850	811.2500	0.0221	0.0570	4.6950	11.3800	0.0050	8.0250	99.7000	12.1650
RS10K680080	U/S Kilpedder Wwtp	09/01/2024	1	1057	0.039	0.32	3.2	9.8	0.008	7.6	88	10.5
RS10K680080	U/S Kilpedder Wwtp	09/04/2024	0.7	480	0.019	0.03	3.6	11.3	0.005	7.6	97	8.8
RS10K680080	U/S Kilpedder Wwtp	06/08/2024	0.8	468	< 0.01	0.03	3.8	10.5	< 0.005	7.7	97	12
RS10K680080	U/S Kilpedder Wwtp	08/10/2024	0.7	369	0.018	0.01	2.5	10.1	0.005	7.7	93	11.9
		Mean	0.8000	593.5000	0.0208	0.0975	3.2750	10.4250	0.0050	7.6500	93.7500	10.8000
		95%ile	0.9700	970.4500	0.0360	0.2765	3.7700	11.1800	0.0050	7.7000	97.0000	11.9850
RS10K010160	D/S Kilpedder Wwtp	09/01/2024	1	391	0.03	0.11	3.5	11.5	0.038	8.2	99	8.4
RS10K010160	D/S Kilpedder Wwtp	09/04/2024	1.4	752	0.035	0.08	3.4	11.2	0.027	8.2	98	9.5
RS10K010160	D/S Kilpedder Wwtp	06/08/2024	1.8	361	0.022	0.04	3.4	10.4	0.009	8.3	102	14.5
RS10K010160	D/S Kilpedder Wwtp	08/10/2024	0.9	316	0.021	0.04	2.2	10.5	0.011	7.9	98	12.3
		Mean	1.2750	455.0000	0.0270	0.0675	3.1250	10.9000	0.0213	8.1500	99.2500	11.1750
		95%ile	1.7400	697.8500	0.0343	0.1055	3.4850	11.4550	0.0364	8.2850	101.5500	14.1700

Note: Where the concentration in the result is less than the limit of detection (LOD), a value of $LOD/\sqrt{2}$ was used in calculating the mean and 95%ile concentrations.