

Annual Environmental Report

2024



Aughrim

D0222-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 AUGHIRM WWTP - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - AUGHIRM WWTP
 - 2.1.2 EFFLUENT MONITORING SUMMARY - AUGHIRM WWTP
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR AUGHIRM WWTP
 - 2.1.5 SLUDGE/OTHER INPUTS TO AUGHIRM WWTP

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 PEARL MUSSEL REPORT
- 5.2 PRIORITY SUBSTANCES ASSESSMENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

- 7.1 AMBIENT MONITORING SUMMARY

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER

This Annual Environmental Report has been prepared for D0222-01, Aughrim, in Wicklow in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable. Refer to Section 4.2.2.

The BOD non-compliance in 2023 has now been resolved with the installation of caustic dosing. The WWTP was fully compliant with the UWWTD in 2024.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Aughrim WWTP with a Plant Capacity PE of 1500, the treatment type is 2 - Secondary treatment.

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF3400D0222SW001	Aughrim WWTP	Treated	Non-Compliant	Ammonia-Total (as N) mg/l

1.4 LICENCE SPECIFIC REPORTING

Assessment / Report
There are no Licence Specific Reports included in this AER.

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 AUGHRIM WWTP - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - AUGHRIM WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Suspended Solids mg/l	12	252	66
BOD, 5 days with Inhibition (Carbonaceous) mg/l	12	333	88
COD-Cr mg/l	12	875	204
Hydraulic Capacity	N/A	2108	451

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF3400D0222SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	12	N/A	N/A	24	Pass
BOD, 5 days with Inhibition (Carbonaceous) mg/l	25	50	N/A	12	N/A	N/A	3.49	Pass
Suspended Solids mg/l	25	62.5	N/A	12	N/A	N/A	6.89	Pass
pH pH units	6	9	N/A	12	N/A	N/A	7.12	Pass
Ammonia-Total (as N) mg/l	5	6	N/A	12	1	1	1.08	Fail
ortho-Phosphate (as P) - unspecified mg/l	5	6	N/A	12	1	N/A	1.35	Pass
Total Nitrogen mg/l	N/A	N/A	N/A	12	N/A	N/A	13	
Total Phosphorus (as P) mg/l	N/A	N/A	N/A	12	N/A	N/A	1.74	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

Cause of Exceedance(s):

WWTP not designed for N removal.

Significance of Results:

The WWTP is non compliant with the ELV's set in the Wastewater Discharge Licence. The impact on receiving waters is assessed further in Section 2.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF3400D0222SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Upstream	313088, 179508	RS10A020120	No	No	No	No	Moderate
Downstream	313357, 179452	RS10A020140	No	No	No	No	Moderate

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**,

Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence for the following: Ammonia-Total (as N) mg/l.

The ambient monitoring results do not meet the required EQS at the upstream monitoring location. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in BOD concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

Domestic waste water and urban runoff are cited as the significant pressures on the Aughrim (Wicklow)_010 At Risk waterbody.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - AUGHRIM WWTP

2.1.4.1 Treatment Efficiency Report - Aughrim WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
SS	10603	1111	90
COD	32747	3796	88
cBOD	14134	562	96

Note: The above data is based on sample results for the number of dates reported.

2.1.4.2 Treatment Capacity Report Summary - Aughrim WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Aughrim WWTP	
Peak Hydraulic Capacity (m ³ /day) - As Constructed	810
DWF to the Treatment Plant (m ³ /day)	270
Current Hydraulic Loading - annual max (m ³ /day)	2108
Average Hydraulic loading to the Treatment Plant (m ³ /day)	451
Organic Capacity (PE) - As Constructed	1500
Organic Capacity (PE) - Collected Load (peak week) ^{Note1}	1869
Organic Capacity (PE) - Remaining	0
Will the capacity be exceeded in the next three years? (Yes/No)	Yes

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - AUGHRIM WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2024.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
Uncontrolled release	Inadequate Infrastructure	No	Yes
Uncontrolled release	Blocked Sewer	No	No
Breach of ELV	WWTP not designed for N removal	Yes	No

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
Abatement equipment off-line	Plant or equipment breakdown at WWTP	No	Yes

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2024	4
Number of Incidents reported to the EPA via EDEN in 2024	4
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2024 (No. of events)	Total volume discharged in 2024 (m ³)	Monitoring Status
SW002 (SWO from Primary Tank)	313206, 179460	Yes	Low Significance	Meeting Criteria	179	9225.55	Monitored
SW003 (SWO from Inlet Works)	313159, 179472	Yes	Low Significance	Meeting Criteria	177	4316.49	Monitored

The contents presented in this table include the most up to date information available at the time of writing. Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much wastewater discharge by metered SWOs during the year (m ³)?	13542
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0222-SIP:01	Cease the discharge of partially treated waste water from the primary settlement tank at the WWTP.	C	31/12/2017	No	Not Started		
D0222-SIP:02	Relocate the emergency overflow associated with Roddenagh Road pumping station from Aughrim fishing lake to the Aughrim River	C	31/07/2015	Yes	Completed		
D0222-SIP:03	Secondary Discharge Point to be discontinued	C	31/12/2017	Yes	Not Started		
D0222-SIP:04	Upgrade Aughrim WWTP to provide sufficient treatment capacity to cater for the volume of waste water arising in the agglomeration	C	31/12/2017	Yes	Not Started		

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
Aughrim WWTP is currently in Stage 2 Preliminary Business Case. Upon completion of Stage 2, funding will be sought to continue to Stages 3 (Final Business Case) and 4 (Implementation) during RC4. However, having regard to the current funding constraints expected in RC4 there is a significant risk to UÉ being in a position to commence or complete this project within the RC4 investment cycle at this time.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Included in this AER
D0222-01-Pearl Mussel Report	Yes	No
D0222-01-Priority Substances Assessment	Yes	No

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	Yes
List reason e.g. additional SWO identified	Capital upgrade
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	Yes
List reason e.g. changes to monitoring requirements	Ambient Monitoring Location Changes
Have these processes commenced?	No
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 30/04/2025

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of,

Eleanor Roche

Head of Environmental Regulation.

7 APPENDIX

Appendix

Appendix 7.1 - Ambient monitoring summary

Aughrim 2024 Ambient Monitoring Summary

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish National Grid Reference (Easting, Northing)	EPA Feature Coding Tool code	Receiving Waters Designation (Yes/No)			
			Bathing Water	Drinking Water	FWPM	Shellfish
Upstream Monitoring Point	313088, 179508	RS10A020120	No	No	No	No
Downstream Monitoring Point	313357, 179452	RS10A020140	No	No	No	No

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Current WFD Status	cBOD (Mean mg/l/l)	o-Phosphate (as P) (Mean mg/l)	Ammonia (as N) (mean mg/l)
Upstream Monitoring Point	Moderate	1.350	0.0115	0.070
Downstream Monitoring Point	Moderate	1.375	0.0115	0.065
<i>Difference</i>		<i>0.025</i>	<i>0.0000</i>	<i>-0.005</i>
EQS		1.500	0.035	0.065
% of EQS		1.667%	0.000%	-7.692%

Aughrim 2024 Ambient Monitoring Data

StationName	Sample Date	BOD	Nitrite N	Ortho P	Ammonia	pH	DO %	DO	Temp	Conductivity
		mg/l	mg/l	mg/l	mg/l	pH Units	%Sat	mg/l	Deg C	µS/cm
Upstream	06/02/2024	1.6	0.006	0.016	0.07	7	98	11.1	9.8	227
Upstream	07/05/2024	1.7	0.005	0.013	0.06	7.1	100	10.8	11.9	106
Upstream	04/09/2024	1.2	0.011	0.012	0.11	6.9	100	10.6	12.4	99
Upstream	05/11/2024	0.9	0.006	0.005	0.04	6.9	101	11.2	11	99
	Mean	1.350	0.007	0.012	0.070	6.975	99.750	10.925	11.275	132.750
	95%ile	1.685	0.010	0.016	0.104	7.085	100.850	11.185	12.325	208.850
Downstream	06/02/2024	2	0.006	0.017	0.08	6.9	98	11.2	9.8	220
Downstream	07/05/2024	1.5	0.006	0.013	0.07	7	100	10.8	11.8	104
Downstream	04/09/2024	1.1	0.012	0.011	0.08	6.8	101	10.8	12.4	93
Downstream	05/11/2024	0.9	0.007	0.005	0.03	6.8	102	11.3	11	95
	Mean	1.375	0.008	0.012	0.065	6.875	100.250	11.025	11.250	128.000
	95%ile	1.925	0.011	0.016	0.080	6.985	101.850	11.285	12.310	202.600

Note: Where the concentration in the result is less than the limit of detection (LOD), a value of LOD/sqrt(2) was used in calculating the mean and 95%ile concentrations.