

# Annual Environmental Report

2024



Longford

D0060-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 LONGFORD WWTP - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - LONGFORD WWTP
  - 2.1.2 EFFLUENT MONITORING SUMMARY - LONGFORD WWTP
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR LONGFORD WWTP
  - 2.1.5 SLUDGE/OTHER INPUTS TO LONGFORD WWTP

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

- 5.1 PRIORITY SUBSTANCES ASSESSMENT

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

### **7 APPENDIX**

- 7.1 AMBIENT MONITORING SUMMARY

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER

This Annual Environmental Report has been prepared for D0060-01, Longford, in Longford in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There were no capital works, significant changes or operational changes undertaken in 2024.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Longford WWTP with a Plant Capacity PE of 20000, the treatment type is 3NP - Tertiary N&P removal.

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF2000D0060SW001	Longford WWTP	Treated	Non-Compliant	Ammonia-Total (as N) mg/l

## 1.4 LICENCE SPECIFIC REPORTING

Assessment / Report
There are no Licence Specific Reports included in this AER.

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 LONGFORD WWTP - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - LONGFORD WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Total Nitrogen mg/l	12	140	50
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	12	592	257
Suspended Solids mg/l	12	2350	778
pH pH units	12	7.50	7.27
Ammonia-Total (as N) mg/l	12	52	24
Total Phosphorus (as P) mg/l	12	27	6.4
COD-Cr mg/l	12	2878	784
Hydraulic Capacity	N/A	12994	6143

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

## Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

### 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF2000D0060SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	13	N/A	N/A	33.75	Pass
Suspended Solids mg/l	35	87.5	N/A	13	N/A	N/A	8.57	Pass
Temperature °C	25	25	N/A	13	N/A	N/A	12	Pass
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	15	30	N/A	13	N/A	N/A	2.6	Pass
Fats, Oils and Greases mg/l	15	18	N/A	4	N/A	N/A	5.43	Pass
pH pH units	6	9	N/A	13	N/A	N/A	7.64	Pass
Total Phosphorus (as P) mg/l	1	1.2	N/A	13	N/A	N/A	0.13	Pass
Ammonia-Total (as N) mg/l	0.8	1.6	N/A	13	1	1	0.47	Fail

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
ortho-Phosphate (as P) - unspecified mg/l	0.44	0.53	N/A	13	N/A	N/A	0.03	Pass
Nitrate (as N) mg/l	N/A	N/A	N/A	12	N/A	N/A	10.1	
Visual Inspection Descriptive	N/A	N/A	N/A	12	N/A	N/A	N/A	
Total Nitrogen mg/l	N/A	N/A	N/A	12	N/A	N/A	11.78	
Nitrate (as NO3) mg/l	N/A	N/A	N/A	12	N/A	N/A	43.2	
Conductivity @20°C µS/cm	N/A	N/A	N/A	13	N/A	N/A	839.7	
Nitrite (as N) mg/l	N/A	N/A	N/A	3	N/A	N/A	0.209	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

### Cause of Exceedance(s):

Inadequate Operational Procedure/Training.

### Significance of Results:

The WWTP is non compliant with the ELV's set in the Wastewater Discharge Licence. The impact on receiving waters is assessed further in Section 2.

### 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE

#### TPEFF2000D0060SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Downstream	211645, 275909	RS26C010900	No	No	No	No	Moderate

*Note: There are no upstream ambient monitoring requirements under the WWDL D0060-01*

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**.

#### Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence for the following: Ammonia-Total (as N) mg/l.

The ambient monitoring results do not meet the required EQS downstream. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

As per the 3rd Cycle Upper Shannon Catchment Report (HA 26C), the significant pressures on the At Risk Camlin\_060 waterbody are Hydromorphology, Urban Runoff, Agriculture and Urban Wastewater.

It is unknown if the discharge from the wastewater treatment plant is having an observable negative impact on the water quality and on the Water Framework Directive status.



## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - LONGFORD WWTP

### 2.1.4.1 Treatment Efficiency Report - Longford WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
<b>cBOD</b>	576569	5839	99
<b>COD</b>	1757074	75682	96
<b>SS</b>	1745468	19217	99
<b>TN</b>	111610	26402	76
<b>TP</b>	14383	299	98

Note: The above data is based on sample results for the number of dates reported.

### 2.1.4.2 Treatment Capacity Report Summary - Longford WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Longford WWTP	
Peak Hydraulic Capacity (m <sup>3</sup> /day) - As Constructed	12000
DWF to the Treatment Plant (m <sup>3</sup> /day)	4000
Current Hydraulic Loading - annual max (m <sup>3</sup> /day)	12994
Average Hydraulic loading to the Treatment Plant (m <sup>3</sup> /day)	6143
Organic Capacity (PE) - As Constructed	20000
Organic Capacity (PE) - Collected Load (peak week) <sup>Note1</sup>	14111
Organic Capacity (PE) - Remaining	5889
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.1.5 SLUDGE / OTHER INPUTS - LONGFORD WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
<b>Domestic /Septic Tank Sludge</b>	20000	Volume (m <sup>3</sup> )	244	0.89	Yes	No	No
<b>Waterworks Sludge</b>	38000	Volume (m <sup>3</sup> )	463	1.69	Yes	No	No
<b>Other</b>	20000	Volume (m <sup>3</sup> )	244	0.89	Yes	No	No

### 3 COMPLAINTS AND INCIDENTS

#### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2024.			

#### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

##### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
Breach of ELV	Inadequate Operational Procedures/Training	No	Yes

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2024	1
Number of Incidents reported to the EPA via EDEN in 2024	1
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2024 (No. of events)	Total volume discharged in 2024 (m³)	Monitoring Status
SW2	212689, 275688	Yes	Low Significance	Meeting Criteria	Unknown	89782	Monitored
TBC	213238, 277951	Yes	Low Significance	Meeting Criteria	0	0	Monitored
TBC	212771, 274726	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
TBC	213319, 275682	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
TBC	213405, 275729	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored

The contents presented in this table include the most up to date information available at the time of writing. Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much wastewater discharge by metered SWOs during the year (m³)?	89782
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	No

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0060-SIP:01</b>	Discharge from SW2 shall comply with the definition of a SWO, as defined in DoEHLG 'Procedures & criteria in relation to SWOs', by 30/06/11	A	30/06/2011	Yes	Works Completed		

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0060-SIP:02</b>	WWTP and Ancillary works Phase Note 1 (Increased plant capacity to 30,000p.e.)	C	30/06/2011	Yes	Works Completed		
<b>D0060-SIP:03</b>	WWTP and Ancillary works Phase Note 1 (Pipeline to the R. Shannon to convey treated effluent.)	C	30/03/2011	Yes	Not Started		Capital works not funded in RC3. Capital works funding post 2024 will be contingent on the project being included in the 2025-2029 investment period.

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

## 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
<b>No additional improvements planned at this time.</b>				

## 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.



## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Included in this AER
D0060-01-Priority Substances Assessment	Yes	No

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	Yes
List reason e.g. changes to monitoring requirements	Ambient Monitoring Location Changes
Have these processes commenced?	No
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 26/04/2025

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of,

Eleanor Roche

Head of Environmental Regulation.

## 7 APPENDIX

### Appendix

#### Appendix 7.1 - Ambient Monitoring Summary

## Longford 2024 Ambient Monitoring Summary

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish National Grid Reference (Easting, Northing)	EPA Feature Coding Tool code	Receiving Waters Designation (Yes/No)			
			Bathing Water	Drinking Water	FWPM	Shellfish
Downstream Monitoring Point	211645, 275909	RS26C010900	No	No	No	No

*Note: There is no upstream monitoring requirement under WWDL D0060-01*

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Current WFD Status	Mean (mg/l)		
		cBOD	o-Phosphate (as P)	Ammonia (as N)
Downstream Monitoring Point	Moderate	1.75	0.034	0.073
EQS		1.500	0.035	0.065

## 2024 Ambient Monitoring Data

StationName	Sample Date	BOD	Total N	Ortho P	Ammonia	pH	DO %	DO	Faecal Coliforms
		mg/l	mg/l	mg/l	mg/l	pH Units	%Sat	mg/l	cfu
Downstream	10/01/2024	1.4	3.2	0.026	0.171	8.02	104.7	11.18	
Downstream	14/02/2024	1.5	0.9	0.019	0.027	7.82	100.1	10.72	981
Downstream	13/03/2024	1.4	2.1	0.042	0.081	7.94	103.1	10.81	
Downstream	10/04/2024	1.4	1.9	0.016	0.028	7.96	102.3	11.02	436
Downstream	08/05/2024	2	0.5	0.013	0.058	8.18	90.2	10.37	
Downstream	12/06/2024	3.7	1.1	0.012	0.038	8.13	94.7	10.39	
Downstream	10/07/2024	1.7	2.45	0.013	0.021	7.86	95.6	9.72	
Downstream	14/08/2024	1.5	1.43	0.067	0.044	7.95		9.91	> 2420
Downstream	11/09/2024	1.20	1.88	0.087	0.031	8.06	88.6	9.95	
Downstream	09/10/2024	2.35	1.84	0.058	0.149	7.76	91.4	9.56	2420
Downstream	13/11/2024	2.18	1.54	0.024	0.174	8.05	84.3	9.58	
Downstream	04/12/2024	<1	1.71	0.034	0.054	8.02	103	11.01	
	<b>Mean</b>	<b>1.75</b>	<b>1.71</b>	<b>0.034</b>	<b>0.073</b>	<b>7.98</b>	<b>96.18</b>	<b>10.35</b>	<b>1387.05</b>
	<b>95%ile</b>	<b>2.96</b>	<b>2.79</b>	<b>0.076</b>	<b>0.172</b>	<b>8.15</b>	<b>103.90</b>	<b>11.09</b>	<b>2313.68</b>

*Note: Where the concentration in the result is less than the limit of detection (LOD), a value of LOD/sqrt(2) was used in calculating the mean and 95%ile concentrations.*