

# Annual Environmental Report

2024



Mullagh

D0252-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 MULLAGH WWTP - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - MULLAGH WWTP
  - 2.1.2 EFFLUENT MONITORING SUMMARY - MULLAGH WWTP -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR MULLAGH WWTP
  - 2.1.5 SLUDGE/OTHER INPUTS TO MULLAGH WWTP

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

- 5.1 PRIORITY SUBSTANCES ASSESSMENT
- 5.2 SMALL STREAM RISK SCORE ASSESSMENT

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

## **7 APPENDIX**

### **7.1 SMALL STREAM RISK SCORE ASSESSMENT**

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER

This Annual Environmental Report has been prepared for D0252-01, Mullagh, in Cavan in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Mullagh WWTP with a Plant Capacity PE of 3000, the treatment type is 3P - Tertiary P removal .

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

| Discharge Point Reference | Treatment Plant | Discharge Type | Compliance Status | Parameters failing if relevant   |
|---------------------------|-----------------|----------------|-------------------|--|
| TPEFF0200D0252SW001       | Mullagh WWTP    | Treated        | Non-Compliant     | Ammonia-Total (as N) mg/l<br>BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l<br>ortho-Phosphate (as P) - unspecified mg/l<br>Suspended Solids mg/l |

## 1.4 LICENCE SPECIFIC REPORTING

| Assessment / Report                |
|------------------------------------|
| Small Stream Risk Score Assessment |

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 MULLAGH WWTP - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - MULLAGH WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

| Parameters  | Number of Samples | Annual Max | Annual Mean |
|---|-------------------|------------|-------------|
| BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l | 12                | 360        | 146         |
| COD-Cr mg/l   | 12                | 955        | 319         |
| Suspended Solids mg/l                               | 12                | 870        | 164         |
| Hydraulic Capacity                                  | N/A               | 1735       | 557         |

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

#### Significance of Results:

The annual mean hydraulic loading is greater than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

## 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF0200D0252SW001

| Parameter  | WWDL ELV (Schedule A) | ELV with Condition 2 Interpretation included Note 1 | Interim % reduction from influent concentration | Number of sample results | Number of exceedances | Number of exceedances with Condition 2 Interpretation included | Annual Mean | Overall Compliance (Pass/Fail) |
|--|-----------------------|---|---|--------------------------|-----------------------|--|-------------|--------------------------------|
| <b>COD-Cr mg/l</b>   | 125                   | 250   | N/A   | 12                       | N/A                   | N/A  | 38.05       | Pass                           |
| <b>Suspended Solids mg/l</b>                               | 25                    | 62.5  | N/A   | 12                       | 6                     | N/A  | 55.23       | Fail                           |
| <b>pH pH units</b>   | 9                     | 9   | N/A   | 12                       | N/A                   | N/A  | 7.24        | Pass                           |
| <b>BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l</b> | 5                     | 10  | N/A   | 12                       | 9                     | 3  | 7.97        | Fail                           |
| <b>Ammonia-Total (as N) mg/l</b>                           | 0.3                   | 0.6   | N/A   | 12                       | 10                    | 9  | 3.18        | Fail                           |
| <b>ortho-Phosphate (as P) - unspecified mg/l</b>           | 0.1                   | 0.2   | N/A   | 12                       | 11                    | 11   | 0.41        | Fail                           |

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

### Cause of Exceedance(s):

Refer to Incident Section of the Report.

## Significance of Results:

The WWTP is non compliant with the ELV's as set in the Wastewater Discharge Licence. The impact on receiving waters is assessed further in Section 2.

### 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF0200D0252SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

| Ambient Monitoring Point from WWDL (or as agreed with EPA) | Irish Grid Reference | River Station Code | Bathing Water | Drinking Water | FWPM | Shellfish | WFD Ecological Status |
|--|----------------------|--------------------|---------------|----------------|------|-----------|-----------------------|
| Upstream   | 268914, 285136       | RS07M060340        | No            | No             | No   | No        | Moderate              |
| Downstream   | 270986, 284095       | RS07M030500        | No            | No             | No   | No        | Poor                  |

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

| Parameter Name            | Upstream Monitoring Point Location | Upstream Monitoring Point Annual Mean | Downstream Monitoring Point Location | Downstream Monitoring Point Annual Mean | EQS   | % of EQS |
|---------------------------|------------------------------------|---------------------------------------|--------------------------------------|---|-------|----------|
| BOD - 5 days (Total) mg/l | RS07M060340                        | 2.10                                  | RS07M030500                          | 0.854                                   | 1.50  | -83.3    |
| Ammonia-Total (as N) mg/l | RS07M060340                        | 0.042                                 | RS07M030500                          | 0.051                                   | 0.065 | 13.8     |



| Parameter Name                                   | Upstream Monitoring Point Location | Upstream Monitoring Point Annual Mean | Downstream Monitoring Point Location | Downstream Monitoring Point Annual Mean | EQS   | % of EQS |
|--|------------------------------------|---------------------------------------|--------------------------------------|---|-------|----------|
| <b>ortho-Phosphate (as P) - unspecified mg/l</b> | RS07M060340                        | 0.029                                 | RS07M030500                          | 0.047                                   | 0.035 | 49.2     |
| <b>pH pH units</b>                               | RS07M060340                        | 7.75                                  | RS07M030500                          | 7.75                                    | N/A   |          |
| <b>Dissolved Oxygen mg/l</b>                     | RS07M060340                        | 9.54                                  | RS07M030500                          | 12                                      | N/A   |          |
| <b>Suspended Solids mg/l</b>                     | RS07M060340                        | 45                                    | RS07M030500                          | N/A                                     | N/A   |          |
| <b>Dissolved Oxygen % O2</b>                     | RS07M060340                        | 96                                    | RS07M030500                          | N/A                                     | N/A   |          |
| <b>Temperature °C</b>                            | RS07M060340                        | 12                                    | RS07M030500                          | 8.65                                    | N/A   |          |

### Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results do not meet the required EQS at the upstream and the downstream monitoring locations. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in Ammonia - Total (as N) & ortho- Phosphate (as P), concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are: Unknown.

The discharge from the wastewater treatment plant does have an observable negative impact on the Water Framework Directive status.

## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - MULLAGH WWTP

### 2.1.4.1 Treatment Efficiency Report - Mullagh WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

| Parameter | Influent mass loading (kg/year) | Effluent mass emission (kg/year) | Efficiency (% reduction of influent load) |
|-----------|---------------------------------|----------------------------------|---|
| cBOD      | 29616                           | 1621                             | 95  |
| TP        | N/A                             | N/A                              | N/A                                       |
| SS        | 33418                           | 11228                            | 66  |
| TN        | N/A                             | N/A                              | N/A                                       |
| COD       | 64813                           | 7735                             | 88  |

Note: The above data is based on sample results for the number of dates reported

### 2.1.4.2 Treatment Capacity Report Summary - Mullagh WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

| Mullagh WWTP   |      |
|--|------|
| Peak Hydraulic Capacity (m <sup>3</sup> /day) - As Constructed | 675  |
| DWF to the Treatment Plant (m <sup>3</sup> /day)               | 225  |
| Current Hydraulic Loading - annual max (m <sup>3</sup> /day)   | 1735 |

| Mullagh WWTP  |      |
|---|------|
| Average Hydraulic loading to the Treatment Plant (m³/day)           | 557  |
| Organic Capacity (PE) - As Constructed                              | 3000 |
| Organic Capacity (PE) - Collected Load (peak week) <sup>Note1</sup> | 1980 |
| Organic Capacity (PE) - Remaining                                   | 1020 |
| Will the capacity be exceeded in the next three years? (Yes/No)     | No   |

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

### 2.1.5 SLUDGE / OTHER INPUTS - MULLAGH WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

| Input type   | Quantity | Unit | P.E. | % of load to WWTP | Included in Influent Monitoring (Y/N)? | Is there a leachate/sludge acceptance procedure for the WWTP? | Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N) |
|--|----------|------|------|-------------------|--|---|--|
| There is no Sludge and Other Input data for the Treatment Plant included in the AER. |          |      |      |                   |  |   |  |

### 3 COMPLAINTS AND INCIDENTS

#### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

| Number of Complaints                                     | Nature of Complaint | Number Open Complaints | Number Closed Complaints |
|--|---------------------|------------------------|--------------------------|
| There were no relevant environmental complaints in 2024. |                     |                        |                          |

#### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

##### 3.2.1 SUMMARY OF INCIDENTS

| Incident Type | Cause                             | Recurring (Y/N) | Closed (Y/N) |
|---------------|-----------------------------------|-----------------|--------------|
| Breach of ELV | WWTP upgrade required to meet ELV | Yes             | No           |

3.2.2 SUMMARY OF OVERALL INCIDENTS

| Question   | Answer |
|--|--------|
| Number of Incidents in 2024                                    | 1      |
| Number of Incidents reported to the EPA via EDEN in 2024       | 1      |
| Explanation of any discrepancies between the two numbers above | N/A    |

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

| WWDL Name / Code for Storm Water Overflow (chamber) where applicable | Irish Grid Ref. (outfall) | Included in Schedule of the WWDL | Significance of the overflow(High / Medium / Low) | Assessed against DoEHLG Criteria | No. of times activated in 2024 (No. of events) | Total volume discharged in 2024 (m3) | Monitoring Status |
|--|---------------------------|----------------------------------|---|----------------------------------|--|--------------------------------------|-------------------|
| SW002  | 270086, 284632            | Yes                              | Low Significance                                  | Not Meeting Criteria             | Unknown  | Unknown                              | Not Monitored     |

The contents presented in this table include the most up to date information available at the time of writing. Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

| SWO Summary   |         |
|---|---------|
| How much wastewater discharge by metered SWOs during the year (m3)?                                   | Unknown |
| Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?      | No      |
| The SWO Assessment included the requirements of relevant of WWDL schedules?                           | No      |
| Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7? | No      |

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

| Specified Improvement Programmes (under Schedule A and C of WWDL) | Description  | Licence Schedule | Licence Completion Date | Date Expired? (N/NA/Y) | Status of Works   | Timeframe for Completing the Work | Comments |
|---|--|------------------|-------------------------|------------------------|-------------------|-----------------------------------|----------|
| <b>D0252-SIP:01</b>   | Complete improvements to comply with ELVs specified in Schedule A. Implement, in accordance with Condition 5.6.1, either (a) improvements to the existing waste water works to achieve compliance with the emission limit values specified in Schedule A.1: Primary Waste Water discharge & Monitoring of this licence, or (b) an alternative primary discharge point, or (c) connection to another agglomeration. | C                | 31/12/2019              | Yes                    | At Planning Stage | 2027                              |          |

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

### 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

| Improvement Identifier                           | Improvement Description / or any Operational Improvements | Improvement Source | Expected Completion Date | Comments |
|--|---|--------------------|--------------------------|----------|
| No additional improvements planned at this time. |   |                    |                          |          |

### 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.



## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

| Licence Specific Report                     | Required by licence | Included in this AER |
|---|---------------------|----------------------|
| D0252-01-Priority Substances Assessment     | Yes                 | No                   |
| D0252-01-Small Stream Risk Score Assessment | Yes                 | Yes                  |

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

| Parameter  | Answer |
|--|--------|
| Does the AER include an Executive Summary?   | Yes    |
| Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)? | Yes    |
| Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?  | N/A    |
| List reason e.g. additional SWO identified   | N/A    |
| Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc   | N/A    |
| List reason e.g. changes to monitoring requirements  | N/A    |
| Have these processes commenced?  | N/A    |
| Are all outstanding reports and assessments from previous AERs included as an appendix to this AER   | No     |

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:    Date: 23/05/2025

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Head of Environmental Regulation.

## 7 APPENDIX

### Appendix

#### Appendix 7.1 - Small Stream Risk Score Assessment

# **SSRS Compliance Monitoring: *Mullagh* Waste Water Treatment Plant 2024**



**Report to Uisce Éireann**  
**Limnos Consultancy, January 2025**

## Contents

|                                      |   |
|--------------------------------------|---|
| Introduction .....                   | 3 |
| Methodology .....                    | 3 |
| Small Streams Risk Score (SSRS)..... | 3 |
| Physico-Chemical Measurements .....  | 4 |
| Location of Sites Sampled .....      | 5 |
| Results .....                        | 6 |
| Site Photographs.....                | 6 |
| Macroinvertebrates – SSRS.....       | 7 |
| Physico-Chemical Results.....        | 9 |
| Summary .....                        | 9 |
| Reference .....                      | 9 |

# Mullagh WWTP

## Introduction

Small Streams Risk Score (SSRS) assessments on the Mullagh River upstream and downstream of the Mullagh waste water treatment plant (WWTP) are outlined in this report. The assessments were made on 14 October 2024. Limnos Consultancy was contracted by Irish Water to undertake the surveys.

## Methodology

### Small Streams Risk Score (SSRS)

Samples were taken using an ISO compliant kick-sampling method compatible with the Environmental Protection Agency (EPA) Standard Operating Procedure for sampling aquatic macroinvertebrates. Samples were taken upstream and downstream of the discharge from the WWTP. SSRS results were assigned based on the macroinvertebrate fauna.

The author was the main initiator of the SSRS system developed by the Western River Basin District and the EPA under his supervision in 2005–2006 (McGarrigle 2014). He has undertaken SSRS training of local authority and other professional staff at the Local Government Water Services Training Centres around the country for over 100 personnel.

The SSRS was calculated based on selected sub-groups of the macroinvertebrates recorded. The score is calculated based on the number of taxa and their relative abundance in four main invertebrate groups as follows:

Group 1: Ephemeroptera (excluding *Baetis rhodani*)

Group 2: Plecoptera

Group 3: Trichoptera

Group 4: GOLD (Gastropoda, Oligochaeta, Diptera)

Group 5: *Asellus*

The first three groups above, mayflies, stoneflies, and caddis flies, are regarded as pollution-sensitive whereas gastropods, oligochaetes, dipterans and *Asellus* are relatively pollution-tolerant. The maximum score that can be achieved is 11.2 and threshold scores deciding the degree of risk of not being at good ecological status are as follows:

- > 7.25 Probably not at risk
- > 6.5 to 7.25 Indeterminate
- < 6.5 Stream may be at risk.

Samples were taken with a standard 1 mm mesh pond net. A 3-minute kick sample was combined with a 1-minute stonewash. Samples were placed on a white tray and, once cleaned of debris such as leaves and twigs and excessive sand or gravel by decanting and hand picking, the sample was examined carefully to identify the macroinvertebrates. At least 25 minutes were spent identifying and assigning each taxon found to a relative abundance category. Table 1 gives the definition of the relative abundance terms Few, Common, Numerous, Dominant and Excessive. The numeric code is used in the results tables below.

***Table 1. Relative abundance table.***

| <b>Abundance</b> | <b>Number of Individual Specimens</b> | <b>Relative abundance numeric code</b> |
|------------------|---------------------------------------|--|
| Few:             | 1 to 5 individuals                    | 1                                      |
| Common:          | 6 to 20                               | 2                                      |
| Numerous:        | 21–50                                 | 3                                      |
| Dominant:        | 51 to 100                             | 4                                      |
| Excessive:       | >100                                  | 5                                      |

### Physico-Chemical Measurements

Physico-chemical measurements were also made for dissolved oxygen, temperature and conductivity using a HACH HQ40d meter with appropriate compatible probes. Probes were calibrated before sampling.



### Location of Sites Sampled

Figure 1 maps the sampling sites and Table 2 gives the details of the locations sampled.



**Figure 1. Location of upstream and downstream monitoring sites for Mullagh WWTP. River flows North.**

**Table 2. Location of sites sampled upstream and downstream of Mullagh WWTP.**

| Location | Mullagh WWTP<br>Upstream | Mullagh WWTP<br>Downstream |
|----------|--------------------------|----------------------------|
| EPA Code | RS07M060340              | RS07M030500                |
| Station  | Bridge at Brookfield     | Ballintlieve Bridge        |
| River    | Mullagh Lough<br>Stream  | Moynalty                   |
| Easting  | 268914                   | 271950                     |
| Northing | 285136                   | 283260                     |

## Results

### Site Photographs

Figure 2 shows photographs taken when sampling upstream and downstream of the Mullagh WWTP on 14 October 2024.

|   |  |
|---|--|
|   |   |
| U/S Mullagh WWTP looking downstream   | U/S Mullagh WWTP looking upstream  |
|  |  |
| D/S Mullagh WWTP looking downstream   | D/S Mullagh WWTP looking upstream  |

***Figure 2. Upstream (U/S) and downstream (D/S) of Mullagh WWTP.***

## Macroinvertebrates – SSRS

Table 3 shows the macroinvertebrate taxa recorded at both sites on 14 October 2024.

**Table 3. Macroinvertebrates recorded upstream and downstream of Mullagh WWTP discharge point.**

|            |         |                                 | Upstream<br>Mullagh<br>WWTP | Downstream<br>Mullagh<br>WWTP |
|------------|---------|---------------------------------|-----------------------------|-------------------------------|
|            |         | 0                               | Mullagh L.<br>Stream        | Moynalty                      |
|            |         |                                 | 07M060340                   | 07M030500                     |
|            |         |                                 | West Br in<br>Mullagh       | Ballintlieve<br>Br            |
|            |         |                                 | 14/10/2024                  | 14/10/2024                    |
| SSRS Group |         | Taxon                           |                             |                               |
| 1          | Ephem   | <i>Ecdyonurus</i>               | -                           | Few                           |
| 1          | Ephem   | <i>Rhithrogena semicolorata</i> | -                           | Few                           |
| 3          | Trich   | <i>Hydropsyche</i>              | -                           | Common                        |
| 3          | Trich   | <i>Sericostoma personatum</i>   | Few                         | -                             |
| 4          | GOLD    | Ancylidae                       | -                           | Few                           |
| 4          | GOLD    | Chironomidae                    | Common                      | Few                           |
| 4          | GOLD    | <i>Lymnaea peregra</i>          | -                           | Few                           |
| 4          | GOLD    | <i>Potamopyrgus antipodarum</i> | Few                         | Dominant                      |
| 4          | GOLD    | Simuliidae                      | -                           | Common                        |
| 4          | GOLD    | Tipulidae                       | Few                         | Few                           |
| 4          | GOLD    | Tubificidae                     | Common                      | Few                           |
| 5          | Asellus | <i>Asellus aquaticus</i>        | -                           | Common                        |
|            | n/a     | <i>Baetis rhodani</i>           | Few                         | Numerous                      |
|            | n/a     | <i>Crangonyx</i>                | -                           | Few                           |
|            | n/a     | <i>Elmis aenea</i>              | Few                         | Few                           |
|            | n/a     | <i>Gammarus</i>                 | Dominant                    | Few                           |
|            | n/a     | Hydrachnidae                    | Common                      | -                             |
|            | n/a     | <i>Limnius volckmari</i>        | -                           | Few                           |
|            | n/a     | Planaria                        | Common                      | -                             |
|            |         |                                 |                             |                               |
|            |         | <b>Number Taxa</b>              | <b>10</b>                   | <b>16</b>                     |
|            |         | <b>SSRS</b>                     | <b>4</b>                    | <b>3.2</b>                    |
|            |         | <b>Q-Value</b>                  | <b>Q3</b>                   | <b>Q3-4</b>                   |



The SSRS grouping to which they belong is shown where relevant – not all families or orders are included in the SSRS method. The taxa are ordered from top to bottom broadly in terms of their sensitivity to pollution with *Ecdyonurus* at the top being the most sensitive and Tubificidae and *Asellus* at the bottom being the most tolerant.

The upstream site on the smaller Mullagh Lough Stream had 10 types and there were 16 recorded at the downstream site on the main Moynalty River. The upstream site is in poor condition with an SSRS of 4 and a Q-Value of Q3. The stream flows from Mullagh Lough and may be impacted by the lake's condition. Agricultural influences are apparent in the upper catchment. The site lacked both Group 1 Ephemeroptera and Group 2 Plecoptera but had a single Trichoptera, the cased caddis *Sericostoma*. *Gammarus* was the dominant type and Tubificidae were common together with chironomids and flatworms. The main difference between this sample and the 2023 sample is the lack of Simuliidae in 2024 – they were numerous in October 2023 at the upstream site. This may be a sign of instability as typically the faunal composition does not vary in rivers and streams from year to year – the more common types usually re-occur in successive samples.

The upstream site is dominated by foals watercress with a coverage of ~80%.

The downstream site on the River Moynalty had 16 taxa but scored a low SSRS of 3.2 despite having both *Ecdyonurus* and *Rhithrogena* from Group 1 in low numbers. The main change is the dominance of *Potamopyrgus* in 2024 – its abundance was low in 2023. *Gammarus* dropped from dominant in 2023 to just 'Few' in 2024. Similarly, *Baetis rhodani* numbers increased from 'Few' in 2023 to 'Numerous' in 2024. The tolerant taxon *Asellus aquaticus* was common in 2024 but absent in 2023. As indicated above, it is unusual to see such major changes in the dominant types from year to year.

Other pressures may be impacting the Moynalty. At the time of writing, the EPA had not published any newer data than the 2020 biological monitoring results but it is likely that it was surveyed in 2023.

As discussed in the 2023 report, ideally, to give a more accurate assessment of the impact of the WWTP, the downstream site should be on the Mullagh Lough Stream but access to this is difficult especially in high flows in winter. It can be accessed in low flow by wading downstream from Mullagh Bridge and sampling just upstream of the confluence of the two water bodies.

## Physico-Chemical Results

Table 4 presents the physico-chemical results for the two sites. The dissolved oxygen of 87.2% at the upstream site is relatively poor and it is likely to drop significantly during the hours of darkness. The faunal composition discussed above reflects the poor oxygenation conditions.

**Table 4. Physico-chemical results for Mullagh River, 14 October 2024.**

| Station                 | Dissolved Oxygen (DO) % Saturation | DO mg/l | Temp. °C | Conductivity µS/cm | pH   |
|-------------------------|------------------------------------|---------|----------|--------------------|------|
| Upstream Mullagh WWTP   | 87.2                               | 9.54    | 10.90    | 383                | 7.85 |
| Downstream Mullagh WWTP | 101.0                              | 11.13   | 10.70    | 235                | 7.56 |

## Summary

The Mullagh River is in poor condition before it reaches the Mullagh WWTP possibly due to the influence of Mullagh Lough – while the SSRS value of 4 was unchanged, the Q-Value dropped to Q3 – poor condition, due to the lack of any of the Group A Q-Value taxa.

The Moynalty site downstream of the confluence with the Mullagh Lough Stream and the WWTP discharge showed an improvement compared with 2023 due to the occurrence of two of the more sensitive mayflies, *Ecdyonurus* and *Rhithrogena*. There were, however, some changes in the main taxa that is a bit concerning suggesting changing pressures on the system at this point.

To rule out whether these changes are related to the WWTP, a sample site on the Lough Mullagh Stream upstream of the confluence with the Moynalty would be required. Access via the WWTP to the stream is required.

## Reference

McGarrigle, M. 2014. "Assessment of Small Water Bodies in Ireland." *Biology and Environment* 114B(3). doi: 10.3318/BIOE.2014.15.